

**OFFICE OF CONSTRUCTION AND PROCUREMENT CELL (CPC)**  
**CWPRS, KHADAKWASLA PUNE 411024**  
**MINUTES OF PREBID MEETING HELD ON 22/05/2024**

**Name of Work:** Water proofing of bed in wave flume in RWFF Hanger near CERC building, CWPRS, Pune 24

**Reference:** Tender Reference No. NIT -01/2024-25.

A pre bid meeting as mentioned in the Tender Notice vide the office NIT No. 01/2024-25 referred above was held at 15:00 hrs on 22/05/2024 in the O/o Scientist-C, CPC, CWPRS, Pune-24.

Shri P. A. Kashyape, Sc-C (I/C Execution, CPC) presented the background of the entire proposed work, its objective and scope of work. Shri M. M. Vaidya (Sc-D, RWFF) and Shri. D. Sharma (RA, RWFF) further contributed to the discussion.

Five agencies were present in the meeting and indicated their awareness regarding the work through the advertisement of e-procurement.


Few clarifications were given as follows (regarding the above subject) for the points discussed during Pre-Bid Meeting.

Sl No.	Query	Clarification
1.	Demolition of RCC wall to bring in excavation machinery.	The RCC should not be demolished under any circumstances since the same has been constructed monolithically to hold and sustain water pressure. Any damage/demolition to the wall may cause leakage from it. Furthermore caution should be excised so as not to damage it.
2.	The lift for excavated material considered in item no. 7 in the Schedule of Work is not sufficient enough.	At the time of execution the payment to the agency will be made as per the actual measurements.
3.	The lead for disposal of stone blocks considered in item no. 10 in the Schedule of Work is not sufficient enough.	At the time of execution the payment to the agency will be made as per the actual measurements.
4.	Waterproofing of Diffraction Basin.	The agency needs to ensure that the joints between the acrylic sheets are watertight as per instructions of the Model Officer and Engineer-in-Charge.

The meeting ended with a vote of thanks to and from the chair.

All terms and conditions mentioned in the tender document will remain unchanged including date of bid submission and bid opening.

Name of the officers and agencies/representatives who attended the pre-bid meeting is annexed herewith. Minutes of the pre-bid meeting are part of the tender document.



(R. R. Bhate)  
Scientist-C

Construction and Procurement Cell